



G&L Consultancy Ltd

Specialists in Asbestos Management

DECONTAMINATION UNIT CLEARANCE AIR MONITORING			
Certificate Reference Number:	J019462/AC03	Client Order No. (if applicable)	N/A
Sampling Date:	18 Nov 2012	Project: (if applicable)	
Client Name and Address:	Abbey Contracting Ltd, Unit 8 & 9, Wirral Park, Glastonbury, Somerset, BA6 9XE		
Site Address:	Regal Theatre, The Avenue, Minehead, Somerset		
Registration/Reference:	AMS		
Removal Contractor Name and Address:	Abbey Contracting Ltd, Unit 8 & 9, Wirral Park, Glastonbury, Somerset, BA6 9XE		
Inspecting/Sampling Officer:	Jason Monger		
Fibre Counting Analyst:	Jason Monger	Time Arrived on site:	10:00
Reason for Sampling:	Clearance tests in DCU following environmental clean of Asbestos Insulation wall containing Unknown		

Sampling carried out by our own officers follows the procedures documented in our internal method M4 – The Sampling of Air, by Personal and Static Means, for Analysis to Determine the Airborne Asbestos Fibre Concentrations. Analysis has been carried out in accordance with our internal method M1 – The Measurement of Asbestos Fibre Concentrations, in Air, by Light Microscopy. Both these internal methods follow the standard methods as outlined in the HSE Literature 'Asbestos: The analysts' guide for sampling, analysis and clearance procedures.' Any deviations from these standard methods are detailed above. No responsibility is taken for sampling that is not carried out by our own officers. Opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. G & L Consultancy Ltd does not accept any responsibility for any stages of the Certificate of Reoccupation that have not been carried out by persons directly employed by G & L Consultancy Ltd. This test report shall not be reproduced, except in full, without the written permission of the laboratory.



G&L Consultancy Ltd

Unit 5A, Chelston Business Park, Castle Road, Wellington, Somerset TA21 9JQ


T 01823 443 898 F 01823 443 154 E somerset@gnl.org.uk W www.gnl.org.uk

Registered Office: Unit 5A, Chelston Business Park, Castle Road, Wellington, Somerset TA21 9JQ

G&L Consultancy Ltd is a company registered in England and Wales with a Company Number: 3687929

Company Directors: Mrs J Lewis and Mr P Lewis. VAT Registration Number: 729 1092 34





VISUAL INSPECTION																	
Decontamination unit free of waste bags, materials and unnecessary equipment						Yes		No visible dust/debris in decontamination unit			Yes						
Negative pressure unit switched off and sealed prior to clearance air monitoring						Yes		Total time taken to complete visual inspection			5 mins						
SAMPLING PLAN (details of sampling area)								Comments: N/A									
<table border="1" style="width: 100%;"> <tr> <td style="width: 33%;">Clean End</td> <td style="width: 33%;">Shower</td> <td style="width: 33%;">Dirty End</td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </table>												Clean End	Shower	Dirty End			
Clean End	Shower	Dirty End															
Area = 4 m ²				Volume = 8 m ³													
Result of Visual Inspection: SATISFACTORY																	
Analyst: Jason Monger			Signed:					Date: 18 Nov 2012		Time: 11:03							
AIR MONITORING																	
Site Ref No	Laboratory Reference No	Pump No	Sampling Period		Flow Rate		Volume (litres) (V)	No of Graticule areas (n)	Fibres (N)	Concentration Fibres/ml	Reported Result fibres/ml						
			Start End	Total Mins	Start End	Total (L/min)											
1	AC000530	C089	11:00	56	10.0	10.0	560	171	3.5	0.001	<0.01						
			11:56		10.0												
Site Temp:			12.7°C			Analysis Location:			Mobile Lab								
Site Pressure:			N/A			Exposed Filter Diameter (D):			22.0mm								
Flowmeter Correction Factor:			N/A			Walton Beckett Graticule (d):			101µm								
Slides Stored In Slide Box No:			JSM1			5th Line Of NSE/NPL Test Slide Observed:			YES								
Comments: N/A																	

Result of Air Monitoring: SATISFACTORY

Analyst:	Jason Monger	Signed:		Date: 18 Nov 2012	Time: 12:02
----------	--------------	---------	---	-------------------	-------------

Following the completion of the clearance air monitoring as detailed above, this decontamination unit is now classed as: SATISFACTORY

Analyst:	Jason Monger	Signed:		Date: 18 Nov 2012	Time: 12:03
----------	--------------	---------	---	-------------------	-------------

Report received by Site Supervisor:		Print name: NATHAN WALFORD
-------------------------------------	---	----------------------------